

Battery Test Results Data Sheet

Job / RMA # Model: Customer:

Serial / Lot Number _____ Contract:
Qty:

Battery Voltage VDC	Capacity %	Pass	Fail
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/>

Tested by _____

Date ____/____/____

100 % of all batteries sets are to be tested
Voltage range 9.6~13.8 VDC (12 VDC / 6 cell battery type)
Minimum battery capacity 85%

QPF 11
Rev-00A
6-1-2012
Approved: PEK